

# CLASSIFICATION REPORT FOR FIRE BEHAVIOUR OF A MATERIAL

Validity 5 years from 13/12/2019

According to the Decree of 21<sup>st</sup> of November 2002 on the reaction to fire performance of construction and furniture Laboratory approved by Ministry of Interior (Decree of 23/03/2010 amending the decree of 05/02/1959 as amended)

« En cas de litige, seule l'édition originale en français du présent procès-verbal fait foi »

Non official Certificate - English translation of attached official Procès-Verbal n° DO-19-1514\A-R1

**Material submitted by:** ASLAN Selbstklebefolien GmbH  
Oberael 2  
51491 Overath  
Germany

**Commercial reference:** Clearboard ASLAN CB 90

**Brief description:** Non fire-retardant self-adhesive PET film  
Fixation method: Self-adhesive (waterbased acrylic adhesive 25 g/m<sup>2</sup>)  
Substrate : Plasterboard (standard substrate defined in the standard NF P 92-507)  
Exposed face : PET film  
Field of application: French Building  
Total nominal thickness (declared by the sponsor): 50 µm.  
Surface density (declared by the sponsor): 75 g/m<sup>2</sup>.  
Color : Transparent.

**Type of test:** NF P 92-501 – Radiation test

**Reference of test report:** DO-19-1514\A-R1 dated on 13/12/2019

**Classification:** **M1** on plasterboard (standard substrate)

**Durability of classification:** Not limited in theory.

Thanks to criteria resulting from tests described in the attached report.

This certificate attests only characteristics of the tested sample and does not prejudice characteristics of similar products. It is therefore not a product certification within the meaning of article L. 115-27 of the consumer code and the act of June 3, 1994.

Valid for applications not covered by EC marking

Valid on the face of use for any application not covered by article AM18 of the ERP regulation concerning the padded seats

Bruay-la-Buissière, 13/12/2019

**Signed**


Signature of the person who realize the classification



Thomas TURF  
Engineer

**Approved**

Signature of the person who authorize the report



Under approval of the president Franck POUTCH  
Skänder KHELIFI  
Technical Manager